

Stack Air Emission Report of Generator-1:

Mondol Intimates Ltd.



Report Prepared BY:

Greentech Testing Company Ltd.

Date of Testing: April 15, 2017

Date of Report Submitting: April 20 2017



Issued By

Description

GREENTECH TESTING COMPANY

Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.



Certificate Number: GT ET/VER/17/2232

Stack Air Emission Report

Greentech Testing Company Ltd.

House No: 4 Sobhanbag, 123 Mohammadia

Super Market (2nd Floor), Mirpur Road,

Dhaka-1207.

Contact Number: 01795-333332 E-mail: info@greentechbd.biz

: April 20, 2017 Date of Issue

: Certificate Number: GT ET/VER/17/2232 **Certificate Number**

Mondol Intimates Ltd. Customer

Shirir Chala, Bager Bazar, Gazipur, Bangladesh.

Stack Air Emission Assessment of Generator. (Included Parameter: Oxygen(O₂), Carbon

Monoxide(CO), Carbon Dioxide(CO2), Nitric

Oxide(NO), Nitrogen Dioxides(NO2), Methane(CH₄), Sulfur Dioxide (SO₂))

Date of Assessment : April 15, 2017

Approved By: Prepared By:

> Ms. Sadia Afrin Nitol **Environmental Specialist**

Head of- Quality Assurance



Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.



Certificate Number: GT ET/VER/17/2232

Stack Air Emission Report

Description of Sampling:

Name of Combustion Unit: Generator (Diesel)

Key Information of Generator	Generator		
Location of Generator	Ground floor, Main Building		
Capacity	280KW		
Brand Name	Perkins		
Supplier Name	Bangla Cat		
Model	NGEP400-3		
Serial No.	OLYOOOOJB500336		
Frequency	50 Hz		
Volts	400/230V		
Manufacturer Year	2012		
Origin	UK		
Relevant Weather Condition			
Temperature of Generator Room	33.38°C		
Humidity of Generator Room	63% RH		
Ambient Weather	Normal		

^{*}N/F= Not Found

Sampling has been done by automatic sampler connected with the analyzer. During the sampling procedure, all instruction stated in the Greentech Testing Company Ltd. work instruction GT-101 has followed. The machine probe has set to the center point of the exhaust. Sampling has been conducted for specific time intervals mentioned in the work instruction and recorded in a field data collection sheet.



Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.



Certificate Number: GT ET/VER/17/2232

Description of Methods:

All the tests have been performed using continuous Stack Emission Monitoring (CEMS) test methods. KANE-940 continuous analyzer was used to monitor CO, SO_2 , CO_2 , NO and NO_X . The analyzer is designed to meet the BS EN 50319 standard method. CO, NO and SO_2 , is measured using electrochemical sensors and CO_2 is measured using

Non-Dispersive Infra-Red (NDIR) method.

Description of Instruments:

Parameter	Resolution	Accuracy	Range	
Temp Measurement Flue with Probe Inlet temperature	1.0 °C/F 0.1 °C/F	± 2.0°C±0.3%reading ±1.0°C±0.3%reading	0-600°C 32-1112°F 0-50°/32-122°F	
Pressure	0.01mbar	± 2% of full scale	+ 150mbar to150mbar	
Gas Measurement Carbon Monoxide (Standard compensated)	0.1% 1ppm	± 2% ± 20ppm<400ppm ±5%<5000ppm ±10%>5000ppm	0-21% 0-10000ppm	
Carbon Monoxide (high range)	0.01%	±5% reading from 0.1% to 10%	0-10%	
Nitric Oxide (Standard)	1ppm	±5ppm<100ppm ±5%>100ppm	0-5000ppm	
Nitric Oxide (Low Range)	1ppm	±2ppm<30ppm ±5ppm>30ppm	0-100ppm	
Nitrogen Dioxide	1ppm	±5ppm<100ppm ±10ppm<500ppm ±5%500ppm	0-1000ppm	
Sulphur Dioxide	1ppm	±5ppm<100ppm ±5%>100ppm	0-5000ppm	
Ambient Operating Range		0°C to 45°C/10% to 90%RH non condensing		



Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.



Certificate Number: GT ET/VER/17/2232

Instrument Calibration:

The temperature probe has been calibrated by temperature simulator EX/R/117. The CO2 sensor has calibrated by using CO test gas, CO standard certified gas, the CO sensor has calibrated by ambient air and standard gas for both lower and higher detection limit. No sensor is calibrated by ambient air and standard certified gas for both lower and higher detection limit respectively. The pressure sensor has calibrated by dead wrights taster and E/C/100 for both lower and higher detection limit respectively. The measured flow rate is tested by TL529 and pump suction is calibrated by EX/X/186.

Measurement Uncertainties:

The uncertainty assigned above measurement is 2 $^{\circ}$ C for temperature, $\pm 2\%$ gas measured and 0.05% for pressure.

Result:

Run	Measured pollutants					
(10 Minutes interval)	CO	CO ₂	NO	NOx	SO ₂	O ₂
	Mg/Nm ³	%	Mg/Nm ³	Mg/Nm ³	Mg/Nm ³	%
Run-1	1090	5.1	276	239	233	12.3
Run-2	1010	5.1	243	238	246	12.4
Run-3	1046	5.1	232	237	238	12.2
Run-4	1047	5.1	287	230	257	12.3
Run-5	1002	5.1	277	238	238	12.4
Run-6	1063	5.1	292	238	243	12.3

Flue Temperature	510°
Differential Flue Pressure	0.13 mbar
P Index	2.25
Excess Air	12.4

Standard Permissible Limit:

	Pollutants						
Agency	CO Mg/Nm ³	CO ₂	NOx Mg/Nm ³	SO ₂ Mg/Nm ³			
DOE	NYS	NYS	150 (GAS) 300 (OIL)	NYS			
US EPA	NYS	NYS	150 (GAS) 300 (OIL)	NYS			
World Bank	NYS	NYS	320 (GAS) 460 (Liquid)	NYS (GAS) 2000 (Liquid)			

*NYS= Not Yet Set




Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.



Certificate Number: GT ET/VER/17/2232

Graphical Presentation of Results:



Graph 1: Graph of emitted gases (CO, SO₂, CO₂, NO, NO_x and O₂) for 60 Minutes

Suspended Particulate Matter (SPM):

D .	Suspended Particulate Matter (µg/m³)						
Run (10 Minutes interval)	PM 0.3	PM 0.5	PM 1.0	PM 2.5	PM 5	PM 10	Total Suspended Particles, TSP(<u><</u> 10μM)
Run-1	2	1	1	26	28	27	85
Run-2	2	1	1	27	25	23	79
Run-3	1	0	0	31	29	32	93
Run-4	2	1	1	30	28	27	89
Run-5	1	1	1	30	27	28	88
Run-6	2	1	1	27	29	26	86

Dhaka-1207.



Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.



Certificate Number: GT ET/VER/17/2232

		utants Conce	ntration	ration			
Agency	NO	H₂S			voc	Hydrocar bon	02
ECR97, Schedule 2, Amendment 2005	NYS	NYS			NYS	NYS	NYS
		AEGL 1	AEGL 2	AEGL 3			
		0.33	17	31			
US EPA	NYS	For 8 Hour Monitoring *AEGL- Acute Exposure Guidelines Levels. (AEGLs), which is indicate the concentrations of the chemical in air above which different types of health effects could begin to occur in an environment. AEGL 1< there may be some discomfort, odor, irritation, but effects, if any, are not impairing and only temporary. AEGL 2< effects become more significant and may impair ability to escape, be long lasting, or permanent. AEGL 3< increasingly severe effects and possible death without treatment.				5% (Assuming a Methane environm ent)	NYS
OSHA	25 ppm	20 ppm (50 ppm for 10 min once if no other measurable exposure occurs.)			NYS	NYS	19.5 – 22 % (for employee) 19.5 – 23.5 % (Atmospheric)

^{*}NYS - Not Yet Set

Suspended Particular Matter (SPM) Standard limit

Agency	SPM Density
	SPM: 200 μg/m³ (8hr Average)
According to ECR 97 (Amendment 2005), Schedule-2	PM 2.5: 15 μg/m³ (Annual Average) 65 μg/m³ (24 hour Average)
	PM 10: 50 μg/m³ (Annual Average) 150 μg/m³ (24 hour Average)
US EPA	PM 2.5-35 μg/m³ (24-hr) PM 10-150 μg/m³ (24-hr)



Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.



Certificate Number: GT ET/VER/17/2232

Discussion and Recommendation:

Stack air emission of "Mondol Intimates Ltd. "of Generator factory has been analyzed for the concentration of parameters CO, CO2, NO2, CH2O and SO2. The concentration of Suspended Particulate Matter (SPM) of different sizes within the range of 0.3 up-1o um has also measured. From the analysis it has been observed that in most of the sections the value of CO, CO2, NO2, CH2O & SO2 are within the maximum permissible limit of ECR 97 Schedule 2 (amendment 2005), US EPA and OSHA guidelines. The Particulate Matter Concentration of some area has exceeded the optimum SPM limit according to ECR97, thus it is recommended to provide mask to the relevant workers of those sections to avoid occupational health hazard. The Oxygen present in the stack emission of Generator found within the acceptable limit.

- 1. The Carbon Monoxide is within the limit for Generator.
- 2. The amount of Nitrogen Dioxide present in the **Generator is** not more than the acceptable Limit.
- 3. Carbon Dioxide found within the acceptable limit in **Generator.**
- 4. Methane found within the permissible limit in Generator.
- 5. Nitric Oxide found not more than the acceptable limit in **Generator.**
- 6. Sulfur Dioxide Found within the DOE and EPA limit in all area.

For obtaining above result the recommendation are given below:

1. Factory has to check Air Emission quality once in a year.

Approved By:


Prepared By:

Ms. Sadia Afrin Nitol Environmental Specialist Head of- Quality Assurance



Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.





Dhaka-1207.



Environmental Testing, Inspection, Assessment, Calibration & Consultancy Organisation.





4 Shobhanbag, 123 Mohammadia Super Market (2nd floor), Mirpur Road, Dhaka-1207.

Web: www.greentechbd.biz **E-mail:** greentech@greentechbd.biz Hotline: +8801795-333332, +880172-7310675, 01612555404

Lab office: Nilu Plaza, 256/A West Dhanmondi,

Dhaka-1209.